



10322 Moursand Blvd.
 San Antonio, Texas 78221
 Tel: 855-744-5222
 Lance: Ext. 3224

28 Day Water Quality and Usage Report

Report Date:	Well Name:
Dec 13 to Jan 9, 2015	
Water Gallons	Recycle Gallons
57,609	n/a

WEEK	Parameter	12/13/2014	12/14/2014	12/15/2014	12/16/2014	12/17/2014	12/18/2014	12/19/2014	Weekly Avg.
		1	Max. Chlorine	0.54	0.55	0.54	0.57	0.55	0.55
	Min. Chlorine	0.46	0.46	0.45	0.45	0.45	0.44	0.38	0.44
	Avg. Chlorine	0.49	0.50	0.49	0.49	0.49	0.49	0.50	0.49
	Max. pH	6.51	6.55	6.58	6.69	6.62	6.50	6.51	6.57
	Min. pH	6.47	6.51	6.54	6.56	6.48	6.45	6.46	6.50
	Avg. pH	6.50	6.53	6.55	6.62	6.56	6.48	6.49	6.53
	Max TDS	20.83	21.43	20.58	21.27	21.12	20.58	21.61	21.06
	Min. TDS	19.73	19.57	19.57	19.73	19.44	19.59	19.02	19.52
	Avg. TDS	20.13	20.21	19.95	20.21	20.10	20.11	20.12	20.12
WEEK	Parameter	12/20/2014	12/21/2014	12/22/2014	12/23/2014	12/24/2014	12/25/2014	12/26/2014	Weekly Avg.
		2	Max. Chlorine	0.59	0.64	0.68	0.64	0.56	0.61
	Min. Chlorine	0.45	0.29	0.41	0.36	0.46	0.40	0.44	0.40
	Avg. Chlorine	0.51	0.49	0.52	0.49	0.50	0.51	0.53	0.51
	Max. pH	6.54	6.53	6.49	6.60	6.63	6.61	6.52	6.56
	Min. pH	6.47	6.48	6.43	6.42	6.55	6.50	6.47	6.47
	Average pH	6.51	6.51	6.46	6.48	6.59	6.57	6.49	6.52
	Max TDS	20.91	21.00	21.30	21.01	20.53	20.83	20.85	20.92
	Min. TDS	19.30	19.75	19.77	19.59	19.66	19.35	19.62	19.58
	Avg. TDS	20.05	20.11	20.27	20.08	20.04	20.07	20.05	20.09
WEEK	Parameter	12/27/2014	12/28/2014	12/29/2014	12/30/2014	12/31/2014	1/1/2015	1/2/2015	Weekly Avg.
		3	Max. Chlorine	0.55	0.54	0.53	0.52	0.53	0.54
	Min. Chlorine	0.47	0.46	0.48	0.48	0.48	0.48	0.43	0.47
	Avg. Chlorine	0.50	0.50	0.50	0.50	0.50	0.51	0.51	0.50
	Max. pH	6.55	6.55	6.49	6.51	6.54	6.53	6.65	6.55
	Min. pH	6.47	6.47	6.45	6.46	6.50	6.50	6.51	6.48
	Average pH	6.50	6.53	6.47	6.49	6.52	6.52	6.55	6.51
	Max TDS	21.01	21.18	20.92	20.58	21.00	20.80	21.16	20.95
	Min. TDS	18.50	19.37	19.08	19.75	18.74	19.35	19.59	19.20
	Avg. TDS	19.99	20.07	20.10	20.19	20.08	20.16	20.19	20.11
WEEK	Parameter	1/3/2015	1/4/2015	1/5/2015	1/6/2015	1/7/2015	1/8/2015	1/9/2015	Weekly Avg.
		4	Max. Chlorine	0.54	0.78	0.55	0.53	0.56	0.52
	Min. Chlorine	0.46	0.46	0.45	0.43	0.45	0.46	0.46	0.45
	Avg. Chlorine	0.50	0.57	0.50	0.50	0.49	0.49	0.50	0.51
	Max. pH	6.56	6.59	6.57	6.62	6.65	6.67	6.69	6.62
	Min. pH	6.45	6.45	6.48	6.52	6.51	6.62	6.62	6.52
	Average pH	6.54	6.50	6.54	6.57	6.56	6.65	6.65	6.57
	Max TDS	20.72	21.38	20.83	21.38	20.45	21.16	20.74	20.95
	Min. TDS	19.80	19.62	19.75	19.75	19.22	19.71	19.73	19.66
	Avg. TDS	20.17	20.21	20.25	20.24	20.01	20.16	20.19	20.18

Remarks

Report prepared by: Lance Freeman Monitoring Analyst		Approved By: Robert Nicol Compliance & Safety Director	
--	--	---	--